

# Forest View Acres Water District

Operations Report – February / March 2018

Prepared by Gabrielle Begeman and Clyde Penn

ORC Water Professionals

## Arapahoe Water Plant

- The plant produced 8% of demand
- Purged Chlorine Analyzer as Needed
- Devin Checked Motor Windings AWP
- Ran plant occasionally – During SWP Backwashes
- Plant Checks, Mixed Chemicals

## Booster Pump Station

- Checked Booster Station

## Distribution

- Meters Read on 26/27 February and 26 / 27 March 2018
- Received List from CRS for none reading METERS – Will check into this ASAP
- Monthly BACTI's Sample

## Surface Water Plant

- The plant produced 92% of demand
- Plant stayed online most of the month, flow rate; running at 35 gpm, inlet pressure holding around 85 - 95 psi. Inlet Pressure Dropping a little bit, Backwashing about every 100 hours.
- Completed monthly MOR report for state
- Pulled Raw Water BACT Samples – Two Times
- Recycle Line Cracked – Parts on Order to Repair
- Plant Checks, Mixed Chemicals

## Locates

- Completed 1 Locates for the Month
  - o Pixie Park / Redstone Ridge Rd - CATV Repair
  - o 4671 Red Rock Ranch Dr – New Water Service
  - o Intersection Sunstar Ct and Sunburst Dr – New CATV Main

## Meters

- Installed New Meter 4671 Red Rock Ranch Dr – New Service
- Have New Gaskets on hand so can start installing more meters

**Projects**

- Shelving AWP – Not Started

**Production for the Month of January 2018**

Year	Month	SWTP Production - BW	% of Total	AWP Production	% of Total	Total Production	Total Water Sold	Percentage Discrepancy
<b>2018</b>	Jan	1,488,302	99%	12,965	1%	1,501,267	1,084,766	27.74%
	Feb	1,573,180	92%	132,550	8%	1,705,730	1,129,429	33.79%
	Mar							
	Apr							
	May							
	Jun							
	Jul							
	Aug							
	Sep							
	Oct							
	Nov							
	Dec							
<b>Total</b>		<b>3,061,482</b>	<b>96%</b>	<b>145,515</b>	<b>4%</b>	<b>3,206,997</b>	<b>2,214,195</b>	<b>30.96%</b>