

Forest View Acres Water District

Operations Report –February 2019

Prepared by Clyde Penn

ORC Water Professionals

Arapahoe Water Plant

- The plant produced 100% of demand for February,
- Purged Chlorine Analyzer as Needed
- Plant Checks, Mixed Chemicals

Booster Pump Station

- Checked Booster Station

Distribution

- Meters were Read on 30 January 2019 and will be read on 26/27 February 2019
- Monthly BACTI's
- Getting pricing on Meter Parts

Surface Water Plant

- The plant produced 0% of demand for February
- Completed monthly MOR report for state – No Violations, using new report dictated by DOVE Inspection
- Plant Checks

Locates

- Completed Locates for the Month
 - o

Meters

- Getting pricing on New Meter Parts – have two people that want old meters changed out as of right now. Once parts come in will schedule for replacement

Production for the Month of August 2018

Year	Month	SWTP Production - BW	% of Total	AWP Production	% of Total	Total Production	Total Water Sold	Percentage Discrepancy
2019	Jan	152,587	8%	1,680,427	92%	1,833,014	1,277,263	30.32%
	Feb	0	0%	1,335,096	100%	1,335,096	1,031,991	22.70%
	Mar							
	Apr							
	May							
	Jun							
	Jul							
	Aug							
	Sep							
	Oct							
	Nov							
	Dec							
Total		152,587	4%	3,015,523	96%	3,168,110	2,309,254	27.11%

2018 Water Leaks:

11 February 2018 – Forest View and Red Forest: Repaired by J&K; Flowed Hydrants after Repairs

27 August 2018 – Sandstone and Pixie Park PRV – Leaking; Parts (SS) on order – Setting up a date for Repair/Training to install parts

27 August 2018 – 4315 Sandstone service line leak – Isolated/Repaired

29 October 2018 Sandstone and Pixie Park PRV – Leaking at outlet pressure gauge – Repaired

08 December 2018 Main Leak Red Forest Rd. – Repaired by Global

23 December 2018 Service Line Leak – 3765 Sierra Vista – Repaired by Homeowner

2019 Water Leaks:

13 March 2019 Service Line Leak – 3830 Range View – Being repaired by homeowner

2019 New Meter Installations / Water Taps:

None to Date