Forest View Acres Water District

Operations Report - March 2023

Prepared by Gabby Begeman -ORC Water Professionals

Arapahoe Water Plant

- The plant effectively produced 100% for March due to the frozen inlet at the SWTP.
- We have received the new chlorine sensor and have installed it at the SWTP. The older but working unit was moved from the SWTP down to the AWP.
- The facility has been operational without difficulties for the month of March.

Booster Pump Station

- The booster pump station PRV was leaking and had to be tightened.
- The booster station has been operational without issues.

Distribution

- Monthly routine bacteriological sample taken and was absent for bacteria.
- Remote monitoring devices have been ordered for the PRV's. They have not yet been received.

Surface Water Plant

- The plant produced 0% in March due to the frozen piping coming from the inlet.
- Completed monthly operations report (MOR) for state with no violations.
- The new turbidimeter display unit has been sent back to HACH for repair.

The chlorine analyzer has been ordered. We have installed a new analyzer at the facility.

Production Totals

Year	Month	SWTP Production - BW	% of Total	AWP Production	% of Total	Total Production	Total Water Sold	Percentage Discrepancy		Average Demand (GPM)
2023	Jan	0	0%	1,607,854	100%	1,607,854	1,217,674	24%	51866	36
	Feb	0	0%	1,430,606	100%	1,430,606	1,094,549	23%	46149	32
	Mar	0	0%	1,418,587	100%	1,418,587	1,176,503	17%	45761	32
	Apr									
	May									
	Jun									
	Jul									
	Aug									
	Sep									
	Oct									
	Nov									
	Dec									
Total		0	0%	4,457,047	100%	4,457,047	3,488,726	22%	47925	33
	Comments:									