Forest View Acres Water District

Operations Report - May 2023

Prepared by Gabby Begeman -ORC Water Professionals

Arapahoe Water Plant

- The plant effectively produced 100% during May.
- The facility has been operational without difficulties for the month of May.

Booster Pump Station

- The booster station has been operational without issues.

Distribution

- Monthly routine bacteriological sample taken and was absent for bacteria.
- Remote monitoring devices have been ordered for the PRV's. They have not yet been received as they are on backorder.
- Reports of low water pressure at 18110 Stone View and of water surfacing at 4710 Red Forest Rd spurred our deployment of a leak detector who found a service line leak at 18110 and a faint leaking sound at 4370 Red Forest. This leak is yet to be repaired. We have not been able to get any contractors with availability.

Surface Water Plant

- The plant produced 0% in May due to the inability to produce water within the regulatory limits of turbidity.
- Completed monthly operations report (MOR) for state with no violations.
- The new turbidimeter display unit has been sent back to HACH for repair.
- The chlorine analyzer has been ordered. We have installed a new analyzer at the facility.

Production Totals

Year	Month	SWTP Production - BW	% of Total	AWP Production	% of Total	Total Production	Total Water Sold	Percentage Discrepancy		Average Demand (GPM)
2023	Jan	0	0%	1,607,854	100%	1,607,854	1,217,674	24%	51866	36
	Feb	0	0%	1,430,606	100%	1,430,606	1,094,549	23%	46149	32
	Mar	0	0%	1,418,587	100%	1,418,587	1,176,503	17%	45761	32
	Apr	0	0%	1,226,013	100%	1,226,013	1,172,053	4%	39549	27
	May	0	0%	1,788,605	100%	1,788,605	1,352,166	24%	57697	40
	Jun									
	Jul									
	Aug									
	Sep									
	Oct									
	Nov									
	Dec									
Total		0	0%	7,471,665	100%	7,471,665	6,012,945	19%	48204	33
	Comments:									